



# 2007 SAFETY BULLETIN

**TO:** All SMACNA Members **SB: 07-01**  
**FROM:** Michael A. McCullion, CSP, ARM  
Director of Safety and Health  
**DATE:** January 25, 2007  
**SUBJECT:** Recall of Electric Safety Switch Units - Square D Company Brand

**SMACNA recently became aware of a product recall that may be applicable to HVAC products. The information below is taken directly from the Square D Company website.**

\*\*\*\*\*

“Our number one priority is the safety of our people, our customers and our products. Because of this, we are working in conjunction with the Consumer Products Safety Commission on a voluntary recall of our Square D 30A & 60A General Duty Switch manufactured between September 11, 2006 and November 4, 2006.

There is the possibility for the switch handle to be placed in the OFF position when the switch is still in an ON (closed) position. This may result in the potential for PERSONAL INJURY OR PROPERTY DAMAGE.

This Notice is applicable ONLY to 30 Ampere and 60 Ampere General Duty Safety Switch Catalog Numbers listed below manufactured between September 11, 2006 and November 4, 2006.

D211NRB	D211NRBBP	D211NRBCP	D221NRB
D221NRBCP	D321NRB	D321NRBCP	DU221RB
DU222RB	DU321RB	DU322RB	

You have associated the Square D brand with industry leadership, safety, quality, reliability and innovation for over 100 years now. You can be assured we will act quickly and appropriately to ensure you receive the quality products and services you have come to expect from us.

Call Square D Company at **1-877-202-9046** toll-free between 7:30a.m. and 5 p.m. ET Monday through Friday for more information about the affected safety switches and obtaining a replacement product.”